

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 37

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

00910	266	54010799	PREF. DEAD END GRIP 160MMSQ ACSR TIGER R..... Each
-------	-----	----------	--

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME CLAMP,ELECTRICAL CONDUCTOR,STR
 AIN
EQUIPMENT USED ON OHTE
MAKERS PART NUMBER ADE 651 DULMISON
STORES DESCRIPTION PRE-FORMED DEAD-END GRIP
 SUITABLE FOR USE ON
 131,23/30,62 SQ MM "TIGER"
 30/7/2,36 STRANDING ACSR WIRE
 DIA 16,52 MM.
 COLOUR CODE BROWN
 TO QUOTED PART NUMBER OR EQUAL

00920	256	54033408	INSULATOR SPNSN; VANDAL PROOF, SI R..... Each
-------	-----	----------	---

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

INSULATOR, SUSPENSION
TYPE VANDAL PROOF
INSULATOR MATERIAL SILICON RUBBER
INSULATOR ATTACHMENT METHOD HOOK AND PIPE FITTING END CAPS
SPECIAL FEATURES CREEPAGE PATH OF 1476 MM
ITEM NUMBER 54033408; EQUIPMENT USED ON OHTE; VANDAL PROOF
DRAWING NO: BBB 3019 REV 4, BBB 3020 REV 1

00930	254	54000920	FEEDER CLAMP 50-161* R..... Each
-------	-----	----------	--

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54000920
APPROVED ITEM NAME SPLICE, CONDUCTOR
SPECIFICATIONS CEE 0063.88/1.
 BS 2874 /LATEST. I.S.O. 6509

DATE:

SIGNATURE OF TENDERER(S):

.....

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 38

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
S.A.B.S. 226/LATEST			
DRAWING NUMBER		CEE-TNB-56	DATE 17.04.2007
		CEE.TNB-57	DATE 17.04.2007
EQUIPMENT USED ON		OHTE	
DESCRIPTION STORES		FEEDER CLAMP	
		50 TO 161 SQ MM	
		COPPER-NICKEL-SILICON.	
		OR ALTERNATIVE MATERIAL	
		DEZINCIFICATION RESISTANT	
		BRASS. (D.Z.R. BRASS)	
		TO BE TESTED IN ACCORDANCE	
		WITH SPECIFICATION BS 2874 OF	
		1986 (LATEST) TO CLAUSE 8 AND	
		APPENDIX "G" ALSO	
		SPECIFICATIONS S.A.B.S. 226	
		I.S.O. 6509 (TEST METHOD)	
00940	252	54003075	TERM. KIT OUTDOOR500MMSQSINGLECOREPEX

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 54003075
 APPROVED ITEM NAME TERMINATION KIT,POWER CABLE
 EQUIPMENT USED ON OHTE
 MAKERS PARTNUMBER EPKT-7D1XO(MOD-PRM) RAYTECH
 STORES DESCRIPTION TERMINATION KIT. OUTDOOR.
 HEAT SHRINK TYPE.
 FOR 500 MM. SQ. SINGLE CORE 3KV.
 SCREENED X.L.P.E S.W.A. CABLE.
 CONSISTING OF: 500 SQ.MM
 COPPER LUG TO DRG. CEE-TN-132
 DATED 1991-10.23.
 9 METRE LONG X 19 MM. WIDE SELF
 VULCANISING ADHESIVE TAPE.
 1 METRE LONG X 30 MM. WIDE
 X 1 MM. THICK MASTIC TAPE
 TWO HOSE CLAMPS TO FIT CABLE
 ARMOURING.
 1 X 185 MM. SQ. ALUMINIUM
 CRIMPING LUG M.12 STUD HOLE.
 INNER SLEEVE 735 MM. LONG.
 OUTER SLEEVE 850 MM. LONG.

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 39

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description	
			COMPLETE WITH ULTRA VOILET PROTECTIVE SKIRT. TO QUOTED PARTNUMBER OR EQUAL.	
00950	230	54034009	DRILL TWST; DE BUIS,DIA 13.5 MM, STL	R..... Each
Delivery Date: 21.12.2010				
FULL DETAILS OF DESCRIPTION				
DRILL, TWIST TYPE DE BUIS DRILL DIAMETER 13.5 MM MATERIAL STEEL FEATURES RAIL DRILLING P/N: NS0234 PERMATOOL FOR DE BUIS TYPE RAIL DRILLING MACHINE				
00960	228	54032528	INSULATOR STD0F;VANDAL PROOF,25 KVAC	R..... Each
Delivery Date: 21.12.2010				
FULL DETAILS OF DESCRIPTION				
INSULATOR, STANDOFF TYPE VANDAL PROOF INSULATOR MATERIAL SILICON RUBBER VOLTAGE RATING 25 KVAC INSULATOR ATTACHMENT METHOD SQUARE TONGUE AND SPADE FITTING SPECIAL FEATURES CREEPAGE PATH 1476 MM P/N: UNKNOWN ELECTRICAL MOULDED COMPONENTS ITEM NUMBER: 54032528; EQUIPMENT USED ON; OHTE DRAWING NO: BBB0429 REV 4, BBB0430 REV 3				
00970	226	54009302	BRIDGE STEADY ARM STAINLESS CURVED	R..... Each
Delivery Date: 21.12.2010				
FULL DETAILS OF DESCRIPTION				
ITEM NUMBER 54009302 APPROVED ITEM NAME STEADY ARM DRAWING NUMBER CEE-TN -0152 AMEND 01 STORES DESCRIPTION STEADY ARM.				

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 40

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
00980	226	54014850	BRIDGE STEADY ARM. OD = 25.4 MM. TOLERANCE +0-0.75 WALL THICKNESS = 2 MM MINIMUM AFTER MANIPULATION. HARDNESS = 180-270 BRINELL. ELONGATION = 6 % MINIMUM ON 25.4 MM GAUGE LENGTH AT 0.02 % OFFSET. ULTIMATE TENSILE STRESS = 486 N/MM SQ. MINIMUM. MATERIAL = AISI 304 WELDED.
			R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER: 54014850
APPROVED ITEM NAME: SPLICE, CONDUCTOR
DESCRIPTION STORES: FEEDER CLAMP
 80/100 TO 107 SQ MM
 COPPER-NICKEL-SILICON
 OR ALTERNATIVE MATERIAL
 DEZINCIFICATION RESISTANT
 BRASS (D.Z.R BRAZZ)
 TO BE TESTED IN ACCORDANCE
 WITH SPECIFICATION BS 2874 OF
 1986 (LATEST) TO CLAUSE 8 AND
 APPEND "G" ALSO
 SPECIFICATIONS S.A.B.S. 226
 I.S.O. 6509 (TEST METHOD)
DESCRIPTION USERS: FOR 80/100 SQ MM STRANDED
 COPPER CATENARY TO 107 SQ MM
 CONTACT WIRE
SPECIFICATIONS: CEE 0063.88/1/LATEST
 BS 2874/LATEST I.S.O. 6509
 1986 (LATEST) TO CLAUSE 8 AND
 S.A.B.S. 226/LATEST
DRAWING NUMBER: CEE-TN-182 DATE 17.04.2007
 CEE-TN-334 DATE 17.04.2007
EQUIPMENT USED ON: OHTE

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 41

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

00990	226	54010524	RAIL BOND 610MM LONGX100MMSQ COPPER*
-------	-----	----------	--------------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 54010524
APPROVED ITEM NAME LEAD,ELECTRICAL
DRAWING NUMBER CEE-TU-54 DATE 1989.10.18
STORES DESCRIPTION RAIL BOND.
600 MM LONG X 100 SQ MM.
ANNEALED COPPER CONDUCTOR
COMPLETE WITH FERRULES.

01000	224	54014849	SPLICE CONDCTR,FEEDER CLAMP
-------	-----	----------	-----------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

SPLICE, CONDUCTOR
TYPE FEEDER CLAMP
DIMENSIONS 50/63/70 TO 107 MM2
MATERIAL COPPER/ NICKEL/SILICON
P/N: UNKNOWN WAM METALS (PTY) LTD
ALTERNATIVE MATERIAL DEZINCIFICATION RESISTANT BRASS.(D.Z.R.
BRASS).SPECIFICATIONS CEE.0063.88/1 AND FOR TESTING WITH
SPECIFICATION BS EN12163.BS EN 12167 AND12164 ALSO SANS 226 AND
ISO 6509
DRAWING NO: REV , CEE.TNB-80 DATE 20.04.2009 REV 3, CEE-TNB-81
DATE 20.04.2009 REV 3, CEE.TNB-81 DATE 1997.08.04 REV 0,
CEE.TNB-81 DATE 20.04.2009 REV 3

01010	2,120	54006282	CLEVIS CLAMP TWIN UBOLT TYPE 25KV
-------	-------	----------	-----------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME CLAMP,ELECTRICAL
DRAWING NUMBER CEE-TZ-1- 122 SHT 14&15/LATEST
EQUIPMENT USED ON 5400000

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 42

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

		5406102	
MAKERS PART NUMBER		142-51-001	BICC
STORES DESCRIPTION		CLEVIS CLAMP	
		TWIN "U" BOLT TYPE	
		TO QUOTED PART NUMBER OR EQUAL	
01020	208	54001419	STEADY ARM ATTACHM. FOR PUSH/PULL TUBE
			R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54001419
APPROVED ITEM NAME STEADY ARM ATTACHMENT
DRAWING NUMBER BBB 0375
DRAWING NUMBER BBB 0290
EQUIPMENT USED ON OHTE
STORES DESCRIPTION STEADY ARM ATTACHMENT.
GRADE SG 50. CASTING.
FOR PUSH PULL-OFF TUBE
ASSEMBLY.

01030	206	54001407	TUBE METLC;OD 50 MM,LG 3 M, 4 MM, STL
			R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

TUBE, METALLIC
OUTSIDE DIAMETER 50 MM
TUBE LENGTH 3 M
WALL THICKNESS 4 MM
TUBE MATERIAL STEEL
SURFACE TREATMENT GALVANIZED
PUSH PULL OFF SPECIFICATION SANS 121 DATE 2000, EQUIPMENT USED
ON OHTE
DRAWING NO: CEE-TMHH-16 REV 0, CEE-TND-38 REV 0

01040	204	54001205	LIGHTNING ARRESTER 6,6 KV
			R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 43

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

MATERIAL NUMBER		054001205	
APPROVED ITEM NAME		ARRESTER,LIGHTNING	
EQUIPMENT USED ON		TRANSMISSION LINE	
STORES DESCRIPTION		ARRESTER, LIGHTNING. DISTRIBUTION CLASS 5 KA 6 KV. AC.SUITABLE FOR 6,6 KV. SYSTEMS.EFFECTIVELY EARTHED SYSTEM. THE MINIMUM CLEARANCE FROM CURRENT CARRYING PARTS TO THE MOUNTING BRACKET OR EARTHED STEEL FRAMEWORK AGAINST WHICH THE BRACKET IS MOUNTED SHALL BE 150 MM.	

01050	202	54004978	ENDING CONE WITH WEDGE 107 AND 161 MMSQ R..... Each
-------	-----	----------	---

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER:	054004978
APPROVED ITEM NAME	CLAMP,ELECTRICAL CONDUCTOR,STR AIN
DRAWING NUMBER	CEE-TNB-36
EQUIPMENT USED ON	OHTE
STORES DESCRIPTION	ENDING CONE COMPLETE WITH WEDGE. FOR 107 AND 161 SQ. MM. CONTACT WIRE.

01060	200	54030327	ANGLE BRACKET BT153 R..... Each
-------	-----	----------	---------------------------------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER	54030327
DRAWING NUMBER	CEE-TZ-2-6 SHT 114
PARTNUMBER	BT 153
APPROVED ITEM NAME	BRACKET,ELECTRICAL
EQUIPMENT USED ON	OHTE BRITS-THABAZIMBI
STORES DESCRIPTION	ANGLE BRACKET 60X60X6 MM. ANGLE IRON

DATE:

SIGNATURE OF TENDERER(S):

.....

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 44

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

COMPLETE WITH M12 U BOLT
AND NUTS, TO FIT 42 MM DIA
TUBE.

01070	200	54005138	FERRULE FOR SUPPORT WIRE(COPPER)
-------	-----	----------	----------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 054005138
APPROVED ITEM NAME FERRULE,ELECTRICAL CONDUCTOR
EQUIPMENT USED ON 5400000
 5406100
 5406102
MAKERS PART NUMBER 1016 CA 0040 HAGGIE RAND
STORES DESCRIPTION COPPER FERRULE FOR SUPPORT
 WIRE,REGISTERING ARM


01080	200	54033825	INSULATOR VANDAL 3KV SQ.TONG/PIPE ENDCAP
-------	-----	----------	--

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 54033825
APPROVED ITEM NAME INSULATOR, STRAIN
DRAWING NUMBER BBB0589 VERSION 2
EQUIPMENT USED ON OHTE
STORES DESCRIPTION STRAIN INSULATOR
 VANDAL PROOF 3KV DC.
 COMPRESSION TYPE
 SQUARE TONGUE AND PIPE
 END CAPS



01090	194	54001015	DEADEND STRAIN CLAMP/SPADE ALI800MMSQ
-------	-----	----------	---------------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 45

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
APPROVED ITEM NAME		CLAMP,ELECTRICAL CONDUCTOR,STR	
		AIN	
DRAWING NUMBER		CEE-TNB-025	
EQUIPMENT USED ON		5400000	
		5406700	
		5406701	
SPECIFICATION NUMBER		CEE.0038/LATEST	
STORES DESCRIPTION		CLAMP, STRAIN	
		DEAD END STRAIN CLAMP WITH	
		SPADE TERMINAL, SUITABLE FOR	
		USE ON 800 SQ MM STRANDED	
		ALUMINIUM WIRE.	
01100	180	54001076	DISC INSULATOR 3 KV PORCELAIN*

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54001076
APPROVED ITEM NAME INSULATOR,DISC
DRAWING NUMBER CEE-TNC-18 DATE 96.08.01
EQUIPMENT USED ON OHTE
SPECIFICATION NUMBER SANS 60383 PART 1
STORES DESCRIPTION INSULATOR, DISC. CLASS B
 3 KV. DISC INSULATOR.
 HIGH GRADE PORCELAIN
 TYPE HT. 0345 OR EQUAL.

01110 172 54000515 U BOLT FOR CONCRETE MAGNET BLOCK

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54000515
APPROVED ITEM NAME BOLT,U
EQUIPMENT USED ON OHTE
DRAWING NUMBER CEE-TX-10 ITEM 50 W DATE 27-01-1971
STORES DESCRIPTION U BOLT. M20
 COMPLETE WITH WASHERS AND NUTS.
 HOT DIPPED GALVANISED TO
 SPEC. SANS 121 DATE 2000.

USERS INTEREST FOR USE ON CONCRETE TRACK MAGNET

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 46

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

BLOCK.

01120	166	54016913	PREF. SPLICE 50MM SQ ACSR WIRE RABBIT	R..... Each
-------	-----	----------	---------------------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME SPLICE, CONDUCTOR
EQUIPMENT USED ON OHTE
MAKERS PART NUMBER ALS FT 396
STORES DESCRIPTION PREFORMED SPIRAL SPLICE.
FOR JOINING 50 MM SQ.
ALUMINIUM WIRE.
ACSR 6/1/3,35 STRANDING.
RABBIT.

01130	164	54002134	CROSSSPAN STEADYARM ATTACHMENT	R..... Each
-------	-----	----------	--------------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION MATERIAL NUMBER 054002134
APPROVED ITEM NAME CLAMP, ELECTRICAL
DRAWING NUMBER CEE-TNB-3/LATEST
STORES DESCRIPTION CROSS SPAN FITTING

01140	150	54031648	ALUM. LINER FOR SINGLE FEEDER SUSP. CLAMP	R..... Each
-------	-----	----------	---	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME LINER, EXPENDABLE METAL
DRAWING NUMBER CEE-TNB-89
EQUIPMENT USED ON O.H.T.E
SPECIFICATION NUMBER B.S 1470 GRADE SIC CON.0
STORES DESCRIPTION LINER ALUMINIUM
TO QUOTED DRAWING
TO BE USED WITH SUSPENSION CLAMP
54/1533

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 47

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description	
01150	140	54008798	LIGHTNING ARRESTER CAPACITOR TYPE 3KV*	R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER : 54008798
APPROVED ITEM NAME : ARRESTER,LIGHTNING
EQUIPMENT USED ON : OHTE
SPECIFICATION NUMBER: CEE.0115.86
DESCRIPTION STORES : LIGHTNING ARRESTER.
CAPACITOR TYPE 4 MICRO FARRAD.
3 KV. DC.

01160	136	54004905	SINGLE PURPOSE CANTILEVER CLAMP	R..... Each
-------	-----	----------	---------------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 54004905
APPROVED ITEM NAME CANTILEVER CLAMP
DRAWING NUMBER CEE-TNB-4 SHT.1 AND 2.
EQUIPMENT USED ON OHTE
STORES DESCRIPTION CANTILEVER CLAMP
CLAMP ASSEMBLY
SINGLE PURPOSE TUBULAR
CANTILEVERS.

01170	126	54006597	ENDING CONE WEDGE WITH NOTCH(CONTACT)	R..... Each
-------	-----	----------	---------------------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54006597
APPROVED ITEM NAME CLAMP,ELECTRICAL
DRAWING NUMBER CEE-TNB-38
EQUIPMENT USED ON OHTE
STORES DESCRIPTION CLAMP, ELECTRICAL
END CLAMP WEDGE 8 MM - 9,9 MM
DIA WIRES. WITH NOTCH.

DATE:

SIGNATURE OF TENDERER(S):

.....

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 48

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

01180	126	54010548	RAIL BOND 220MM LONGX50MMSQ COPPER
-------	-----	----------	------------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME LEAD,ELECTRICAL
DRAWING NUMBER CEE-TU-57/LATEST
EQUIPMENT USED ON 5400000
5405700
5405701
STORES DESCRIPTION RAIL BOND.
ANNEALED COPPER CONDUCTOR
COMPLETE WITH FERRULES,
220 MM LONG X 50 SQ MM.

01190	122	54002498	THIMBLE 22 MM DIA.
-------	-----	----------	--------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54002498
APPROVED ITEM NAME THIMBLE ROPE
SPECIFICATION NUMBER SANS 2262 DATE 1984.
EQUIPMENT USED ON OHTE
DRAWING NUMBER CEE-TNB-39 DATE 1995-09-11
STORES DESCRIPTION ORDINARY WIRE ROPE THIMBLE
GALVANIZED TO SANS 121
DATE 2000.
NOMINAL SIZE 22 MM DIA. WIRE.

01200	118	54032488	INSULATOR;TENSION,25 KV,SILICON RUBBER
-------	-----	----------	--

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

INSULATOR
TYPE TENSION

DATE:

SIGNATURE OF TENDERER(S):

.....

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 49

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description	R..... Each
POTENTIAL 25 KV MATERIAL SILICON RUBBER P/N: UNKNOWN ELECTRICAL MOULDED COMPONENTS ITEM NUMBER 54032488; CREEPAGE PATH 1476; VANDAL PROOF; (COMPOSITE) SQUARE TONGUE AND ROUND CLEVIS END CAPS SPECIFICATION: IEC 1109 DRAWING NO: BBB0281 REV 4				
01210	118	54003063	TERM. KIT INDOOR 500MMSQ SINGLECORE/PEX	R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 54003063
 APPROVED ITEM NAME TERMINATION KIT,POWER CABLE
 EQUIPMENT USED ON OHTE
 MAKERS PARTNUMBER EPKT-7D1XI(MOD-PRM) RAYTECH
 JIT 3.3/1X4DC JOINTMASTER
 STORES DESCRIPTION TERMINATION KIT. INDOOR
 HEAT SHRINK TYPE.
 FOR 500 SQ MM. SINGLE CORE 3 KV.
 SCREENED X.L.P.E S.W.A CABLE.
 CONSISTING OF:
 500 SQ.MM.COPPER LUG
 TO DRG.CEE-TN-132.
 9 METRE LONG X 19MM.WIDE SELF
 VULCANISING ADHESIVE TAPE.
 OUTER SLEEVE 330MM. LONG.
 1 METRE LONG X 30MM.WIDE X 1 MM
 THICK MASTIC TAPE.
 TO QUOTED PARTNUMBERS OR EQUAL

01220	110	54001570	CRADLE FOR DOUBLE SUSP. CLAMP	R..... Each
-------	-----	----------	-------------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54001570
 APPROVED ITEM NAME CRADLE,CLAMP
 DRAWING NUMBER CEE-TNB-052
 EQUIPMENT USED ON 5405201
 STORES DESCRIPTION CRADLE, SUSPENSION CLAMP.

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 50

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

GALVANISED MALLEABLE CAST IRON
COMPLETE WITH LUG, FOR USE ON
DOUBLE SUSPENSION CLAMP AND
SUITABLE FOR USE ON STRANDED
COPPER CATENARY AND STRANDED
ALUMINIUM FEEDER WIRES.

01230	108	54028807	CLEVIS FITTING 19,3 MM STEMFORSTEADY/REG	R..... Each
-------	-----	----------	--	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION MATERIAL NUMBER 054028807
APPROVED ITEM NAME CLEVIS, ROD END
DESCRIPTION STORES CLEVIS FITTING 19,3 MM DIA STEM.
STEADY AND REGISTRATION ARMS
25 KV O.H.T.E
DESCRIPTION USERS BRITS-THABAZIMBI
DRAWING NUMBER CEE-TZ-2-6 SH 13

01240	108	54005417	DISC INSULATOR 16 MMB 254X146 PITCH	R..... Each
-------	-----	----------	-------------------------------------	----------------

Delivery Date: 21.12.2010


FULL DETAILS OF DESCRIPTION
ITEM NUMBER 54005417
APPROVED ITEM NAME INSULATOR,SUSPENSION
DRAWING NUMBER CEE-TZ-1-121 SHT 1
STORES DESCRIPTION DISC INSULATOR 16 MM "B"
SOCKET WITHOUT ZINC COLLAR
GLASS 254 DIA X 146 PITCH
25 KV AC OVERHEAD TRACK
EQUIPMENT

01250	108	54002486	LUG 500MMSQ M27*	R..... Each
-------	-----	----------	------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION
ITEM NUMBER 54002486
APPROVED ITEM NAME TERMINAL,LUG
DRAWING NUMBER CEE-TNB-45 DATE 1995.11.15

DATE: SIGNATURE OF TENDERER(S):



RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 51

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
STORES DESCRIPTION TERMINAL LUG			
CABLE SIZE 500 SQ MM			
CLEARANCE HOLE FOR STUD M27			
CRIMP TYPE FOR STRANDED COPPER			
CABLE ON POT HEAD AND BUS-BAR			
CABLES.			
01260	106	54000880	PARALLEL CLAMP 250-160*

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER: 54000880
 APPROVED ITEM NAME: SPLICE, CONDUCTOR
 SPECIFICATION NUMBER: CEE.0063.88/1.
 BS 2874/LATEST I.S.O. 6509
 S.A.B.S. 226/LATEST
 DRAWING NUMBER: CEE-TNB-54 DATE 17.04.2007
 CEE-TNB-55 DATE 17.04.2007
 EQUIPMENT USED ON: OHTE
 DESCRIPTION STORES: PARALLEL CLAMP.
 250 TO 160 SQ MM.
 COPPER-NICKEL-SILICON.
 OR ALTERNATIVE MATERIAL
 DEZINCIFICATION RESISTANT
 BRASS (D.Z.R. BRASS)
 TO BE TESTED IN ACCORDANCE
 WITH SPECIFICATION BS 2874 OF
 1986 (LATEST) TO CLAUSE 8 AND
 APPENDIX "G" ALSO
 SPECIFICATIONS S.A.B.S. 226
 I.S.O. 6509 (TEST METHOD)

01270	84	54001609	ADAPTER PLATE 100 X 50 BOOM SIZE
-------	----	----------	----------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54001609
 APPROVED ITEM NAME ADAPTER PLATE
 DRAWING NUMBER CEE-TNE-35 DATE 200-10-30
 STORES DESCRIPTION ADAPTER PLATE.

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 52

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

		GALVANISED FLAT STEEL. FOR 100 X 50 BOOM	
USERS DESCRIPTION		CATENARY SUSPENSION INSULATOR.	
01280	84	54011530	CROSS CLAMP 80-80 MMSQ (SKILPAD)
			R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME	CLAMP,ELECTRICAL		
DRAWING NUMBER	CEE-TN - 368/LATEST		
EQUIPMENT USED ON	5400000		
	5405801		
STORES DESCRIPTION	ADJUSTABLE CROSS CLAMP. 80 MM TO 80 MM CATENARY WIRE. INDICATED AS C ON DRAWING.		
01290	84	54003795	SPLIT PIN 6.3 MM DIA X 40MM NOMINAL LENGTH
			R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER	54003795		
APPROVED ITEM NAME	PIN,COTTER		
SPECIFICATION NUMBER	SANS 1700-17-1		
STORES DESCRIPTION	SPLIT PIN 6.3 MM DIA X 40 MM NOMINAL LENGTH BRASS		
01300	82	54033457	STRAINCLAMP ASS. 800 MM LAPWING
			R..... Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER	54033457
APPROVED ITEM NAME	CLAMP,ELECTRICAL CONDUCTOR, STRAIN
DRAWING NUMBER	BBB 3589,3597,3590
EQUIPMENT USED ON	OHTE

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 53

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

STORES DESCRIPTION DEAD END STRAIN CLAMP
ASSEMBLY.
SUITABLE FOR 800 MM. SQ.
ACSR WIRE. CODE NAME LAPWING.

01310	78	54000831	BRACKET CANTILEVER STRUT FOR U/C
-------	----	----------	----------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54000831
APPROVED ITEM NAME BRACKET,ELECTRICAL EQUIPMENT
DRAWING NUMBER CEE-TMHC-55/LATEST
EQUIPMENT USED ON OHTE
SPECIFICATION NUMBER CME-9 SYM.8
STORES DESCRIPTION SANS 121 DATE 2000
STRUT, CANTILEVER
FOR UNIVERSAL COLUMN MAST.
100 X 50 X10,6 KG/M X 56 CM
LONG CHANNEL IRON
WITH 2 X 22 MM AND 4 X 18 MM
HOLES
USERS DESCRIPTION 25 KV AC AUTO TENSION
CONSTRUCTION

01320	78	54017082	LUG 50 MM SQ HUCKBOLT*
-------	----	----------	------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54017082
APPROVED ITEM NAME TERMINAL,LUG
DRAWING NUMBER CEE-TU-136 DATE 01.02.2008
EQUIPMENT USED ON OHTE
STORES DESCRIPTION CRIMPING LUG.
CABLE SIZE 50 SQ MM

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 54

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
01330	78	54004157	THIMBLE FOR SECTION INSULATOR

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54004157
APPROVED ITEM NAME THIMBLE,ROPE
DRAWING NUMBER CEE-TNB-8 DATE 1989-10-26
SPECIFICATION BS 4042
EQUIPMENT USED ON OHTE
STORES DESCRIPTION THIMBLE 6 MM.
ALUMINIUM BRONZE DIE CAST.

01340	74	54005531	PREF. SPLICE 160 MM SQ ALI WIRE
-------	----	----------	---------------------------------

R.....
Set

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME SPLICE,CONDUCTOR
EQUIPMENT USED ON 5405802
MAKERS PART NUMBER ALS 640 P.L.P.
STORES DESCRIPTION PREFORMED SPIRAL SPLICE FOR
JOINING 160 SQ MM ALUMINIUM
WIRE
19/3,25 MM STRANDING.
(HORNET).

01350	72	54017716	CLAMPING BRACKET WITH EARTH WIRE CLEAT
-------	----	----------	--

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME BRACKET, ELECTRICAL
DESCRIPTION CLAMPING BRACKET WITH EARTH
WIRE CLEAT.
CANTILEVER & BOOM STRUCTURES
DRAWING NUMBER CEE-TMF-126

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 55

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
01360	72	54001925	TURNBUCKLE 400 TO 460MM M24 SCREWS

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54001925
APPROVED ITEM NAME TURNBUCKLE
DRAWING NUMBER CEE-TNB-019 DATE 21-06-2006
EQUIPMENT USED ON O/HTE
SPECIFICATION NUMBER BS 4429
STORES DESCRIPTION TURNBUCKLE.
 DROP-FORGED 400 MM - 460 MM
 TAKE-UP, M24 SCREWS.
 HOT DIPPED GALVANISED TO SPEC.
 SANS 121 DATE 2000.

01370	70	54011198	CARBON MOULD L/HAND 100MMSQ CU CROWN
-------	----	----------	--------------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 054011198
APPROVED ITEM NAME CARBON BLOCK,WELDING
MAKERS PART NUMBER MRC50LH
SPECIFICATION NUMBER CEE 0163.86/LATEST
STORES DESCRIPTION CARBON MOULD C/W COVER L/HAND
 100 SQ MM COPPER WIRE TO
 RAIL CROWN.
 TO QUOTED PARTNUMBER OR EQUAL.

01380	68	54011101	CARBON MOULD R/HAND100MMSQ CU RAILCROWN
-------	----	----------	---

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 054011101
APPROVED ITEM NAME CARBON BLOCK,WELDING
MAKERS PART NUMBER MRC100RH
SPECIFICATION NUMBER CEE 0163.86/LATEST
STORES DESCRIPTION CARBON MOULD

DATE:

SIGNATURE OF TENDERER(S):

.....

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 56

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
		CARBON MOULD C/W COVER R/HAND 100 SQ MM COPPER WIRE TO RAIL CROWN TO QUOTED PARTNUMBER OR EQUAL.	
01390	68	54002728	PARALLEL CLAMP 160-50*

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 54002728
APPROVED ITEM NAME SPLICE, CONDUCTOR
SPECIFICATIONS CEE. 0063.88/1.
 BS 2874 /LATEST. I.S.O. 6509
 S.A.B.S. 226/LATEST
DRAWING NUMBER CEE-TNB-54 DATE 17.04.2007
 CEE.TNB-55 DATE 17.04.2007
EQUIPMENT USED ON OHTE
DESCRIPTION STORES PARALLEL CLAMP
 160 TO 50 SQ MM
 COPPER-NICKEL-SILICON.
 OR ALTERNATIVE MATERIAL
 DEZINCIFICATION RESISTANT
 BRASS. (D.Z.R. BRASS)
 TO BE TESTED IN ACCORDANCE
 WITH SPECIFICATION BS 2874 OF
 1986 (LATEST) TO CLAUSE 8 AND
 APPENDIX "G" ALSO
 SPECIFICATIONS S.A.B.S. 226
 I.S.O. 6509 (TEST METHOD)

01400	68	54011680	STEADYARM ASS. WITHCLEVISSWIVELSTEMSTAIN
-------	----	----------	--

R.....
Each


Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME PIPE,METALLIC
DRAWING NUMBER CEE-TND-028
EQUIPMENT USED ON 54000000
 54052030
SPECIFICATION NUMBER GRADE 304 AISI

DATE:

SIGNATURE OF TENDERER(S):



RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 57

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
STORES DESCRIPTION		PIPE,METALLIC	STEADY ARM ASSEMBLY,COMPLETE WITH CLEVIS FITTING,SWIVEL CLIP STEM AND STAINLESS STEEL TUBE 25,4 OD X 2,03 WALL THICKNESS X 855 MM LONG OVERHEAD TRACK EQUIPMENT

01410 68 54014951 SURGE ARRESTER STATION CLASS 42 KV RMS
R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54014951
APPROVED ITEM NAME ARRESTER,LIGHTNING
EQUIPMENT USED ON OHTE
PARTNUMBER SBK-III 42/10.2 TRIDELTA
STORES DESCRIPTION SURGE ARRESTER.
PEDESTAL SELF SUPPORTING
STATION CLASS TYPE.
MINIMUM RATING 42 KV RMS
FOR 25 KV 50 HZ SINGLE
PHASE TRACTION SUPPLIES
ARRESTER TO WITHSTAND
MINIMUM TEMPORARY OVERVOLTAGES
OF 48,3 KV FOR 1 SECOND.
WITHOUT INSULATING BASE
TO QUOTED PARTNUMBER.

01420 66 54000386 WASHER MAST BASE IMPERIAL*
R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54000386
APPROVED ITEM NAME INSULATION,WASHER
DRAWING NUMBER CEE-TU-106 DATE 09-04-1990
EQUIPMENT USED ON OHTE
SPECIFICATION NUMBER CEE-0166.96 (IN CONJUNCTION
WITH).
STORES DESCRIPTION WASHER, MAST BASE INSULATION.
ROUND BASE INSULATION

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 58

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

33,5 ID X 76 OD X 2,5 MM THICK

01430	64	54005050	WASHER L FOR SUSPENSION INSULATOR
-------	----	----------	-----------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54005050
APPROVED ITEM NAME WASHER,KEY
DRAWING NUMBER BBB8575 VERSION 1
EQUIPMENT USED ON SUSPENSION INSULATOR
STORES DESCRIPTION WASHER,KEY,RECTANGULAR
 ID 20 MM
 WIDTH 45 MM
 LENGTH 60 MM
 THICKNESS 4 MM
 ONE END PREBENT 15 MM HIGH
 ALUMINIUM

01440	62	54011542	CROSS CLAMP 800-80 MMSQ (SKILPAD)
-------	----	----------	-----------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME CLAMP,ELECTRICAL
DRAWING NUMBER CEE-TN - 368/LATEST
EQUIPMENT USED ON 5400000
 54005801
STORES DESCRIPTION ADJUSTABLE CROSS CLAMP.
 800 MM TO 80 MM CATENARY WIRE.
 INDICATED AS E ON DRAWING.

01450	62	54000981	DEAD END STRAIN CLAMP 500 ALI
-------	----	----------	-------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME CLAMP,ELECTRICAL CONDUCTOR,STR
 AIN

DATE:

SIGNATURE OF TENDERER(S):

.....

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 59

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description	
DRAWING NUMBER		CEE-TNB-025		
EQUIPMENT USED ON		5400000		
		5406700		
		5406701		
SPECIFICATION NUMBER		CEE.0038/LATEST		
STORES DESCRIPTION		CLAMP, STRAIN.		
		DEAD END STRAIN CLAMP,		
		SUITABLE FOR 500 SQ MM		
		STRANDED ALUMINIUM WIRE.		
01460	60	54007275	CLEVIS PIN 20MM DIA X 102 MM LONG	R..... Each
Delivery Date: 21.12.2010				
FULL DETAILS OF DESCRIPTION				
ITEM NUMBER		54007275		
APPROVED ITEM NAME		PIN,STRAIGHT,HEADED		
EQUIPMENT USED ON		OHTE		
MAKERS PART NUMBER		148-025-002 BICC		
STORES DESCRIPTION		CLEVIS PIN		
STORES DESCRIPTION		20 MM DIA X 102 MM LONG		
TENDERERS TO NOTE		ACCORDING TO DRAWING CEE-TX-67		
		LENGTH 55 MM TO BE 102 MM.		
01470	60	54011073	HANDLE CLAMP FOR RAIL WEB	R..... Each
Delivery Date: 21.12.2010				
FULL DETAILS OF DESCRIPTION				
MATERIAL NUMBER		054011073		
APPROVED ITEM NAME		CLAMP,PLIER		
MAKERS PART NUMBER		HCW		
SPECIFICATION NUMBER		CEE.0163.86/LATEST		
STORES DESCRIPTION		HANDLE CLAMP		
		USED ON RAIL WEB.		
		TO QUOTED PARTNUMBER OR EQUAL.		
01480	60	54011692	HOCKEYSTICK ASSWITHCLEVISSWIVELSTEMSTAIN	R..... Each
Delivery Date: 21.12.2010				

DATE:

SIGNATURE OF TENDERER(S):

.....

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 60

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54011692
 APPROVED ITEM NAME PIPE,METALLIC
 DRAWING NUMBER CEE-TND-032 DATE 07-04-1997
 EQUIPMENT USED ON OHTE
 SPECIFICATION NUMBER GRADE 304 AISI
 STORES DESCRIPTION PIPE,METALLIC
 HOCKEY STICK ASSEMBLY,COMPLETE
 WITH CLEVIS FITTING,SWIVEL
 CLIP STEM AND STAINLESS STEEL
 TUBE 25,40 OD X 2,03 WALL
 THICKNESS OVERHEAD TRACK
 EQUIPMENT

01490	58	54002992	C LINK FOR 50MMSQ ALI. ALLOY CONDUCTOR	R.....
				Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 054002992
 APPROVED ITEM NAME SPLICE,CONDUCTOR
 DRAWING NUMBER CEE-PFA-16
 EQUIPMENT USED ON TRANSMISSION LINE CONDUCTORS
 STORES DESCRIPTION CABLE SIZE 50 SQ MM
 "C" LINK, SUITABLE FOR USE ON
 ALUMINIUM ALLOY CONDUCTOR.
 (A.A.C.) STRANDING 7/3.30 AND
 50/9,0 SQ MM ALUMINIUM
 CONDUCTOR.

01500	58	54011174	CARBON MOULD R/HAND 97 STEEL/100CUWEB	R.....
				Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54011174
 APPROVED ITEM NAME CARBON BLOCK,WELDING
 MAKERS PART NUMBER MRW100RH
 SPECIFICATION NUMBER CEE.0163.86/LATEST
 STORES DESCRIPTION CARBON MOULD C/W COVER R/HAND
 97 SQ MM STEEL OR 100 SQ MM CU
 TO RAIL WEB

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 61

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

TO QUOTED PARTNUMBER OR EQUAL.

01510 58 54005607 LUG ALUMINIUM FOR 160MMSQ ALI WIRE M16
R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME TERMINAL,LUG
DRAWING NUMBER CEE-TZ-1- 121 SHT 37
EQUIPMENT USED ON OHTE
MAKERS PART NUMBER 121-161-17 BICC
L40A16 BICCON
STORES DESCRIPTION CRIMPING LUG.
CABLE SIZE 19/3,25
CLEARANCE HOLE FOR STUD M16
ALUMINIUM COMPRESSION LUG FOR
19/3,25 HARD DRAWN ALUMINIUM
WIRE 16,3 MM DIA.
TO QUOTED PART NUMBER OR EQUAL

01520 58 54031523 TURNBUCKLE M20 EYETOEYE 130MM TAKEUP
R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54031523
APPROVED ITEM NAME: TURNBUCKLE
DRAWING NUMBER: CEE-TNB-79 DATE 21-06-2006
STORE DESCRIPTION: TURNBUCKLE
M20 DROP-FORGED EYE AND EYE
130 MM TAKE-UP
COMPLETE WITH ONE LOCKNUT
M20 SCREWS.
HOT DIPPED GALVANISED TO SPEC.
SANS 121 DATE 2000.

01530 56 54002284 ADAPTER PLATE 12MM THICK
R.....
Each

Delivery Date: 21.12.2010

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 62

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

FULL DETAILS OF DESCRIPTION

MATERIAL NUMBER 054002284
 APPROVED ITEM NAME ADAPTER PLATE
 DRAWING NUMBER CEE-TN-52/LATEST
 EQUIPMENT USED ON 5400000
 5405201
 STORES DESCRIPTION ADAPTER PLATE.
 GALVANISED 12 MM THICK (M.S.)
 PLATE.
 SECTION 20/000349

01540	56	54002437	BOW AND CROSS HEAD 36MM DIA	R..... Each
-------	----	----------	-----------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54002437
 APPROVED ITEM NAME BOW AND CROSS HEAD
 DRAWING NUMBER CEE-TNB-050
 EQUIPMENT USED ON OHTE
 STORES DESCRIPTION BOW AND CROSS HEAD.
 GALVANISED ASSEMBLY. 36 MM DIA
 TENSION BRIDGE AND ANCHOR MAST

01550	56	54033016	TUNNEL SUPPORT ASS. 3KV	R..... Each
-------	----	----------	-------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54033016
 APPROVED ITEM NAME TUNNEL, FITTING
 DRAWING NUMBER BBB1684
 EQUIPMENT USED ON OHTE
 STORES DESCRIPTION TUNNEL SUPPORT ASSEMBLY
 FOR DOME ROOF TUNNEL
 3 KV. DC.
 TO QUOTED DRAWING EXCLUDING
 ITEMS 7, 8, 9,10 AND 17.

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 63

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

01560	50	54033381	INSULATOR STD0F; VANDAL PROOF, 25 KVAC
-------	----	----------	--

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

INSULATOR, STANDOFF
TYPE VANDAL PROOF
INSULATOR MATERIAL SILICON RUBBER
VOLTAGE RATING 25 KVAC
INSULATOR ATTACHMENT METHOD ROUND TONGUE AND PIPE FITTING
SPECIAL FEATURES CREEPAGE PATH 1476 MM
P/N: UNKNOWN ELECTRICAL MOULDED COMPONENTS
EQUIPMENT USED ON; OHTE
DRAWING NO: BBB3019 REV 4, BBB3020 REV 1

01570	44	54001594	ADAPTER PLATE 180 MMX70MM BOOM SIZE
-------	----	----------	-------------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54001594
APPROVED ITEM NAME ADAPTER PLATE
DRAWING NUMBER CEE-TNE-35 date 2000-10-30
EQUIPMENT USED ON OHTE
STORES DESCRIPTION ADAPTER PLATE.
GALVANISED FLAT STEEL.
180 X 70 BOOM SIZE

01580	44	54033470	SPLICE 800 MM SQ LAPWING TO LAPWING
-------	----	----------	-------------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54033470
APPROVED ITEM NAME SPLICE, CONDUCTOR
EQUIPMENT USED ON OHTE
DRAWING NUMBER BBB 3593, 3595, 3592
STORES DESCRIPTION TENSION SPLICE
SUITABLE FOR 800 MM SQ

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547
Date : 24.08.2010

Page
64

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
		ACSR TO 800 MM SQ ACSR WIRE.(CODE NAME LAPWING TO LAPWING).	

01590	40	54024316	ARC RUNNER SET 3KV IFC TYPE SECTINS.	R..... Each
-------	----	----------	--------------------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54024316
APPROVED ITEM NAME RUNNER,INSULATOR
PARTNUMBER SI0540 Q-TECH
STORES DESCRIPTION ARC RUNNER SET
FOR 3 KV. IFCO MARK 3
SECTION INSULATOR.
4 RUNNERS PER SET.
TO QUOTED PARTNUMBER OR EQUAL.

01600	40	54006310	BALL SWIVEL CLAMP STEADYARMS AT BRIDGES	R..... Each
-------	----	----------	---	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54006310
APPROVED ITEM NAME HOLDER,CONTACT
DRAWING NUMBER CEE-TZ-1- 122 SHT 18&19
EQUIPMENT USED ON OHTE
MAKERS PART NUMBER 142-057-002 BICC
STORES DESCRIPTION HOLDER, CONTACT.
BALL SWIVEL CLAMP.
STEADY ARM BRIDGES.
TENDERERS TO NOTE ALSO TO DRAWING CEE-TZ-1-123
SHT 13 ONLY TOP CUT OFF
BEFORE GALVANISING

01610	40	54006270	CLEVIS CLAMP SINGLE UBOLT TYPE 25 KV	R..... Each
-------	----	----------	--------------------------------------	----------------

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 65

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

APPROVED ITEM NAME CLAMP,ELECTRICAL
DRAWING NUMBER CEE-TZ-1- 122 SHT 1&2/LATEST
EQUIPMENT USED ON 5400000

5406102

MAKERS PART NUMBER 142-50-001 BICC
STORES DESCRIPTION CLAMP, ELECTRICAL.
CLEVIS CLAMP SINGLE "U" BOLT
TYPE.
TO QUOTED PART NUMBER OR EQUAL

01620	40	54007036	DOUBLE CLEVIS CLAMP H FITTING
-------	----	----------	-------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME CLEVIS,INSULATOR
DRAWING NUMBER CEE-TZ-1-126 SHS 7&8/LATEST
EQUIPMENT USED ON 5400000

5405202

MAKERS PART NUMBER 146-008-001 BICC
STORES DESCRIPTION CLEVIS, INSULATOR.
DOUBLE CLEVIS. (H)

01630	40	54033469	SPLICE 500 MM SQ DEER TO DEER
-------	----	----------	-------------------------------

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54033469
APPROVED ITEM NAME SPLICE,CONDUCTOR
EQUIPMENT USED ON OHTE

DRAWING NUMBER BBB 3593,3594,3592
STORES DESCRIPTION TENSION SPLICE
SUITABLE FOR 500 MM SQ
ACSR TO 500 MM SQ ACSR
WIRE.(CODE NAME DEER TO
DEER).

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 **Page**
Date : 24.08.2010 **66**

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

01640 40 54033660 TENSION SPLICE COMPRESSION TIGER WIRE

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54033660
APPROVED ITEM NAME SPLICE,CONDUCTOR
EQUIPMENT USED ON OHTE
STORES DESCRIPTION TENSION SPLICE MIDSPAN
 COMPRESSION TYPE 160 MM SQ
 SUITABLE FOR 160 MM SQ ACSR
 WIRE (CODE NAME TIGER).
 COMPLETE WITH STEEL INSERT.

01650 38 54011113 CARBON MOULD L/HAND97STEEL/100MMSQCUWEB

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54011113
APPROVED ITEM NAME CARBON BLOCK,WELDING
MAKERS PART NUMBER MRW100LH
SPECIFICATION NUMBER CEE.0163.86/LATEST
STORES DESCRIPTION CARBON MOULD
 CARBON MOULD C/W COVER L/HAND
 97 SQ MM STEEL OR 100 SQ MM CU
 TO RAIL WEB.
 TO QUOTED PARTNUMBER OR EQUAL.

01660 34 54028780 CLEVIS FITTING 35,2 MM STEM FOR REG.TUBE

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME CLEVIS, ROD END
DESCRIPTION STORES CLEVIS FITTING 35,2 MM STEM.
 PUSH OFF REGISTRATRION TUBE FOR
 TANGENT TRACK TYPE 2

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 67

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
------	-----	----------	-------------

25 KV O.H.T.E
DESCRIPTION USERS BRITS-THABAZIMBI
DRAWING NUMBER CEE-TZ-2-6 SH 14
01670 34 54000993 LUG ALI 500MMSQ FOR FEEDER WIRE
R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME TERMINAL,LUG
DRAWING NUMBER CEE-TNB-27
SPECIFICATION NUMBER CEE.0038.87
STORES DESCRIPTION LUG, CRIMPING.
CABLE SIZE 500 SQ MM
COMPLETE WITH BOLTS AND NUTS.
SUITABLE FOR 500 SQ MM
STRANDED ALUMINIUM WIRE.
01680 34 54022544 TENSIONING SPRING FOR CONTACT WIRE 3KV
R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54022544
APPROVED ITEM NAME SPRING,HELICAL,EXTENSION
DRAWING NUMBER CEE-TNB-30
CEE-TNB-33
EQUIPMENT USED ON OHTE
STORES DESCRIPTION SPRING.
CONTACT WIRE TENSIONING
SPRING FOR 3 KV.DC. LINES
01690 32 54002474 CLEVIS SHACKLE STRAP
R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

ITEM NUMBER 54002474
APPROVED ITEM NAME CLAMP,ELECTRICAL
DRAWING NUMBER CEE-TNB-043/LATEST

DATE: SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: VAR-6547 Page
Date : 24.08.2010 68

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

Item	Qty	Material	Description
EQUIPMENT USED ON STORES DESCRIPTION		O.H.T.E. CLEVIS SHACKLE STRAP.	

01700 32 54002069 T-CLAMP ALI. 800MMSQ

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

APPROVED ITEM NAME SPLICE, CONDUCTOR
DRAWING NUMBER CEE-TNB-026
SPECIFICATION NUMBER CEE. 0038/LATEST
STORES DESCRIPTION COMPRESSION TYPE T-CLAMP.
FOR 800 MM. SQ. STRANDED WIRE.
ALUMINIUM.

01710 30 54000867 SPLICE CONDCTR, PARALLEL CLAMP

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

SPLICE, CONDUCTOR
TYPE PARALLEL CLAMP
DIMENSIONS 250 TO100/80 MM2
MATERIAL COPPER/NICKEL/SILICON
P/N: UNKNOWN WAM METALS (PTY) LTD
ALTERNATIVE MATERIAL DEZINCIFICATION RESISTANT BRASS. (D.Z.R.
BRASS) TO BE TESTED IN ACCORDANCE WITH SPECIFICATION BS EN
12163, BS EN 12164, BS EN 12167 ALSO SPECIFICATIONS SANS
226, ISO 6509 (TEST METHOD) AND CEE.0063.88/1. EQUIPMENT USED ON
OHTE
DRAWING NO. REV , REV 0, CEE-TNB-54 DATE 1997.04.18 REV ,
CEE-TNB-54 DATE 20.04.2009 REV 4, CEE-TNB-55 DATE 20.04.2009
REV 4

01720 26 54005215 SWIVEL CLIP RETAINER FOR 107 AND 161

R.....
Each

Delivery Date: 21.12.2010

FULL DETAILS OF DESCRIPTION

DATE: SIGNATURE OF TENDERER(S):