



RFQ / TENDER

Tender No: KGG-13022

Vendor No: 11001386

BOARD LIST
BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT
2000

Purchaser : E. Mundalamo
Telephone : 011 584 1142
Fax Number:

Please quote reference:
D33/6000600356

Deliver to:
TFR Head Office
Supply Chain Services
2000 Johannesburg

Closing Date : 03.03.2014
Validity Date : 03.06.2014
RFQ No : 6000600356

Ihr Zeichen KGG-13022

FOR TECHNICAL ENQUIRIES WITH REGARDS TO THIS RFQ YOU MAY CONTACT
MR GERT VAN RENSBURG, 083 440 4228

THE RFQ DOCUMENTS ARE OBTAINABLE FROM 26/02/2014 TILL 28/02/2014
THE OFFICE OF TRANSNET FREIGHT
RAIL, TENDER ADVISE CENTRE GROUND FLOOR, INYANDA HOUSE 1, 21 WELLINGTON
ROAD, PARKTOWN. DURING OFFICE HOURS FROM 08:00 TO 15:00 AND RFQ
DOCUMENTS IS FOR FREE.

1. RETURN OF QUOTATION/S:

1.1 QUOTATION/S MUST BE SUBMITTED PUNCTUALLY ON THE CLOSING DATE 03/03/2014 AT 10:00 AND LATE QUOTATIONS WILL NOT BE CONSIDERED.

1.2 IF POSTED/ HAND DELIVERY:

THE SECRETARY
TRANSNET ACQUISITION COUNCIL
INYANDA HOUSE 1
21 WELLINGTON ROAD
PARKTOWN
JOHANNESBURG
2001

1.3 IF E-MAILED:

thuli.mathebula@transnet.net

DATE: SIGNATURE OF TENDERER(S):
CONTACT PERSON: TEL No:

RFQ / TENDER

Tender No: KGG-13022 **Page**
Date : 25.02.2014 **2**

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

2. CONDITIONS:

- 2.2 ANY PURCHASE ORDER PLACED AS A RESULT OF YOUR QUOTATION WILL BE SUBJECT TO THE GENERAL CONDITIONS OF PROMAT QUOTATIONS, CONTRACT AND ORDERS, FORM US7 (REVISED 15 APRIL 1993), TENDER PROCEDURES, FORM CSS NO.5 (REVISED 15 APRIL 1993) AND CONDITIONS MENTIONED HEREIN.
- 2.3 TENDERERS MAY OFFER AN EARLIER VALIDITY DATE, BUT THEIR QUOTATION MAY, IN THAT EVENT, BE DISREGARDED FOR THIS REASON.
- 2.4 TENDERERS ARE REQUIRED TO OFFER ONLY FIRM PRICES. PRICES SUBJECT TO REVIEW IN TERMS OF CLAUSE 33(1) OF FORM US7 WILL ONLY BE CONSIDERED SHOULD THE DELIVERY PERIOD REQUIRED EXCEED 6 MONTHS.
- 2.5 BEST DELIVERY TIME MUST BE OFFERED.
- 2.6 DISCOUNT (TRADE DISCOUNT)/CASH DISCOUNT (CONDITONAL DISCOUNT)/ VALUE ADDED TAX (VAT) MUST BE SHOWN SEPARATELY.
- 2.7 TRANSNET RESERVES THE RIGHT TO NEGOTIATE PRICES AND COMMERCIAL ASPECTS AFTER THE CLOSING DATE OF THE QUOTATION.

"PREVIEW COPY ONLY"

DATE:

SIGNATURE OF TENDERER(S):

RFQ / TENDER

Tender No: KGG-13022 Page
Date : 25.02.2014 3

BOARD LIST
TRANSNET FREIGHT RAIL
PROCUREMENT DEPARTMENT

SCHEDULE OF REQUIREMENTS

TENDERERS SHOULD INSERT THEIR PRICE/S UNDER THE APPROPRIATE HEADINGS HEREUNDER.

IN THIS REGARD THE TENDERER'S ATTENTION IS DIRECTED TO PARAGRAPH 2 OF THE TENDER PROCEDURES OF FORM CSS NO.5.

NB. TENDERERS OFFERING GOODS FROM IMPORTED SUPPLIES MUST SUBMIT THEIR PRICES ON THE DELIVERY BASIS APPEARING UNDER COLUMN (C) OF THIS SCHEDULE OF REQUIREMENTS.

3. EVALUATION CRITERIA

3.1 COMPLIANCE TO SPECIFICATION

3.2 COMPETITIVE PRICING AND B-BBEE

Item	Qty	Material	Description	R.....
00010	1	vanguard Ezct-S2A	Current Transformer Ex	Each

Delivery Date: 15.04.2014

FULL DETAILS OF DESCRIPTION

"PREVIEW COPY ONLY"

DATE:

SIGNATURE OF TENDERER(S):

Specification
Current transformer tester

TYPE: Portable current transformer test set

PHYSICAL SPECIFICATIONS: 16.8"W x 12.6"H x 12"D (42.7 cm x 32 cm x 26.9 cm); Weight: 48 lbs (21 kg)

INPUT POWER: 100 – 120 Vac or 200 – 240 Vac (factory pre-set), 50 Hz/60 Hz

MEASUREMENT METHOD: ANSI/IEEE C57.12.90, IEC 60044-1 and ANSI/IEEE C57.13.1

OUTPUT TEST VOLTAGES: 0 – 50 Vac @ 10A max, 0 – 250 Vac @ 10A max
0 – 500 Vac @ 5A max, 0 – 1500 Vac @ 1.2A max

VOLTAGE READING RANGE: 0 – 2,200 Vac; Accuracy: $\pm 1.0\%$ of reading, ± 1 volt

CURRENT READING RANGE: 0 – 10A; Accuracy: $\pm 1.0\%$ of reading, $\pm 0.02A$

CURRENT RATIO RANGE: 0.8 – 999: 0.1%, 1000 – 1999: 0.3%, 2000 – 5000: 1%

PHASE ANGLE MEASUREMENT: 0 - 360 degrees; Accuracy: ± 1.0 degree

DISPLAY: Back-lit LCD Screen (240 x 128 dot graphic; 114mm x 64mm); viewable in bright sunlight and low light levels

PRINTER: Built-in 4.5-Inch wide thermal printer

COMPUTER INTERFACES: One RS-232C port (115k baud), one USB port

PC SOFTWARE: Windows® XP/Vista-based CT Analysis software is included with purchase price

INTERNAL TEST RECORD STORAGE: Stores 140 test records. Each test record may contain up to 10 sets of excitation, resistance and ratio data

INTERNAL TEST PLAN STORAGE: Stores 128 test plans. Each test plan can store 10 excitation test voltage and current settings

SAFETY: Designed to meet UL 61010A-1 and CAN/CSA C22.2 No. 1010.1-92 standards

ENVIRONMENT: Operating: -10° to 50° C (15° F to $+122^{\circ}$ F); Storage: -30° C to 70° C (-22° F to $+158^{\circ}$ F)

CABLES: Two 20-foot X cable sets, One 35-foot H cable set, power cord, One cable-carrying duffel bag

WARRANTY: One year on parts and labor

TO BE ORDERED: 1